



NOTE:

1. UPS BACKUP MINIMUM 30 MIN.
2. EARTHING SHOULD BE WATERED ONCE IN A WEEK.
3. N STANDS FOR NEUTRAL AND L STANDS FOR PHASE(LINE) SHOULD BE RIGHT SIDE.
4. VOLUME CAPACITY OF COMPRESSOR TANK SHOULD BE MINIMUM 0.25 M³ (250 LTR).

REV. AS ON W/HAMPGOUTANS620082016